

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 13-51-07833
Name of Facility: Golden Glades El.
Address: 16520 NW 28 Avenue
City, Zip: Hialeah 33054

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: MDCPS
Person In Charge: Kayla Edwards Phone: 3056249641
PIC Email: PR2161@dadeschools.net

Inspection Information

Purpose: Routine
Inspection Date: 3/16/2026

Begin Time: 09:38 AM
End Time: 10:40 AM

Additional Information

FEMALES 80
MALES 76

CENSUS 156

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN	11. Group Toilet Rooms	IN	21. Pest Control
IN 1. School Site	OUT	12. Toilet Facilities		SAFETY
IN 2. Playground, Equip & Athletic Fields*	OUT	13. Handwashing Facilities	IN	22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN	14. Soap Dispensers		DIAPER CHANGING STATION
BUILDING CONST/MAINT.	IN	15. Shower Facilities	NA	23. Sanitizers
IN 4. Construction	IN	16. Showers Water Temperatures	NA	24. Changing Station & Mats
OUT 5. Maintenance & Repair		WATER SUPPLY	NA	25. Hand Sink
IN 6. Lighting Standards	IN	17. Approved Source	NA	26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN	18. Drinking Fountains		ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation		LIQUID WASTE & WASTE WATER	NA	27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN	19. Sewage Disposal		DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN	20. Solid Waste	IN	28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation		PEST CONTROL	IN	29. Other

Marking Key: **IN** = the act or item was observed to meet standards; **OUT** = the act or item was observed not to meet standards; **NO** = the act or item was not observed to be occurring at the time of inspection; **NA** = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Satisfactory.

Email Address(es): PR2161@dadeschools.net;
Lsmart1234@dadeschools.net;
yteague@dadeschools.net;
wcabrera@dadeschools.net;
mwertz@dadeschools.net;
lpalacio@dadeschools.net;

Violations Comments

Violation #5. Maintenance & Repair

At the time of this inspection, A/C out of service were observed in classrooms # 14 and 1. Repair or replace A/C out of service.

At the time of this inspection, missing ceiling tiles were observed in the Art Room. Replace ceiling tiles.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #12. Toilet Facilities

At the time of this inspection, a toilet out of service was observed in restroom # 014. Repair or replace toilet.

CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

Violation #13. Handwashing Facilities

At the time of this inspection, a handwashing sink out of service was observed in restroom # 017. Repair or replace handwashing sink.

At the time of this inspection, the hand dryer machine was observed out of service in restroom # 017. Repair or replace hand dryer machine.

At the time of this inspection, paper towels were observed missing in the restroom located in classroom # 2. Provide paper towels.

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Inspection Conducted By: Pedro Hernandez Bastidas (60752)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name: Latoya Smart
Date: 3/16/2026

Inspector Signature:

Client Signature: